

**DELAWARE DEPARTMENT OF TRANSPORTATION  
MATERIALS AND RESEARCH LABORATORY  
BOX 778 800 BAY ROAD DOVER, DE 19903  
302-760-2400  
Concrete Admixture**

Lab No.	Contract No
Color	Section            812
Sampled At	Date Sampled
Supplied By	Date Received
Sampled From	Date Tested
Supply Location	Represents

<u>ASTM: C-494</u>	<u>Sample</u>	<u>Specification</u>
Solids (%)		5.6% - 6.4%
Specific Gravity		
PH		11.5 - 13.5

Remarks:

This sample does conform with the Manufacturer's Specifications and therefore is approved for use.

Testing Technician \_\_\_\_\_ Date \_\_\_\_\_

Lab Supervisor \_\_\_\_\_ Date \_\_\_\_\_

Lab Manager \_\_\_\_\_ Date \_\_\_\_\_